

PROPOSED ADA SIGNAGE PLAN

BUILDING B

SCALE: 1/8" = 1'-0"

- AREA SIGNAGE NOTES:
- A) REQUIRED ACCESSIBLE ELEMENTS SHALL BE IDENTIFIED BY THE INTERNATIONAL SYMBOL OF ACCESSIBILITY AT THE FOLLOWING LOCATIONS:
 - A) ACCESSIBLE RESTROOMS. REFER TO ADA SIGN LOCATION PLAN FOR LOCATIONS.
 - B) ACCESSIBLE EXITS. REFER TO ADA SIGN LOCATION PLAN FOR LOCATIONS.
 - C) ACCESSIBLE PARKING SPACES. REFER TO PROPOSED SITE PLAN FOR LOCATIONS.
 - D) ACCESSIBLE ENTRANCE. REFER TO ADA SIGN LOCATION PLAN FOR LOCATIONS. HANDICAPPED ACCESSIBLE ENTRANCE DIRECTIONAL SIGNAGE SHALL BE LOCATED AT NON-ACCESSIBLE ENTRANCE. DIRECTIONAL SIGNAGE SHALL INCLUDE THE INTERNATIONAL SYMBOL OF ACCESSIBILITY AND SHALL INDICATE THE ROUTE TO THE ACCESSIBLE ENTRANCE.
02. ALL SIGNAGE SHALL COMPLY WITH ADA SIGNAGE REQUIREMENTS.

701.1 Scope. Communications elements and features required to be accessible by the scoring provisions indicated by the administrative authority shall comply with the applicable provisions of Chapter 7.

702.1 Means. Accessible audio and visual alarm and notification appliances shall be installed in accordance with NFPA 72 listed in Section 106.2.2, be powered by a commercial light and power system, and be electrically connected to the wiring of the premises electric system, and be permanently installed.

703 Signs

703.1 General. Accessible signs shall comply with Section 703.1.

703.2.1 General. Visual characters shall comply with Section 703.2.

EXCEPTION: Visual characters complying with Section 703.3 shall not be required to comply with Section 703.2.

703.2.2 Case. Characters shall be uppercase, lowercase, or a combination of both.

703.2.3 Style. Characters shall be conventional in form. Characters shall not be italic, oblique, script, highly decorative, or of other unusual forms.

703.2.4 Character Height. The uppercase letter "T" shall be used to determine the allowable height of all characters of a font. The uppercase letter "C" at characters of a font. The uppercase letter "I" shall be used to determine the allowable height of the uppercase "T" of the font.

703.2.5 Character Width. The uppercase letter "T" shall be used to determine the allowable width of all characters of a font. The width of the letter "C" shall be used to determine the allowable width of the uppercase "T" of the font. The center minimum and 110 percent maximum of the width of all characters of a font.

703.2.6 Stroke Width. The uppercase letter "T" shall be used to determine the allowable stroke width of all characters of a font. The stroke width shall be 10 percent minimum and 50 percent maximum of the height of the uppercase "T" of the font.

703.2.7 Character Spacing. Spacing shall be measured between the two closest points of word spaces. Spacing between individual characters shall be 10 percent minimum and 50 percent maximum of the character height.

703.2.8 Contrast. Characters shall be measured against a background that is a minimum of 70 percent contrast with the characters.

703.2.9 Depth. Tactile characters shall be raised 1/16 inch (1.6 mm) minimum above the background.

703.3.1 General. Tactile characters shall comply with Section 703.3.

703.3.2 Braille. Braille shall be installed in accordance with Section 703.3.2.

703.3.3 Position. Braille shall be installed in accordance with Section 703.3.3.

703.3.4 Mounting Height. Braille shall be installed in accordance with Section 703.3.4.

703.3.5 Pictograms. Pictograms shall be installed in accordance with Section 703.3.5.

Table 703.2.4—Visual Character Height

| Height above Floor to Baseline of Character | Horizontal Viewing Distance | Minimum Character Height |
|--|---|--|
| 40 inches (1015 mm) to less than or equal to 70 inches (1780 mm) | Less than 6 feet (1830 mm) and greater | 1/4 inch (6.35 mm), 1/4 inch (6.35 mm) distance above 6 feet (1830 mm) |
| Greater than 70 inches (1780 mm) to less than or equal to 120 inches (3050 mm) | Less than 15 feet (4570 mm) and greater | 2 inches (51 mm) |
| Greater than 120 inches (3050 mm) | Less than 21 feet (6400 mm) and greater | 3 inches (75 mm) |




Fig. 703.2.4



Fig. 703.2.5




Fig. 703.2.6



Fig. 703.2.7



Fig. 703.2.8




Fig. 703.2.9




Fig. 703.2.4




Fig. 703.2.5



Fig. 703.2.6




Fig. 703.2.7




Fig. 703.2.8



Fig. 703.2.9

ICSNAB A117.1-2003



Fig. 703.4.3



Fig. 703.4.4



Fig. 703.4.5




Fig. 703.4.6



Fig. 703.4.7



Fig. 703.4.8



Fig. 703.4.9

Table 703.4.3—Braille Dimensions

| Measurement range | Minimum in inches | Maximum in inches |
|---|----------------------------------|------------------------------------|
| Dot base diameter | 0.089 (1.5 mm) to 0.093 (1.6 mm) | 0.093 (1.5 mm) to 0.097 (1.6 mm) |
| Distance between two dots in the same cell | 0.089 (2.3 mm) to 0.100 (2.5 mm) | 0.241 (6.1 mm) to 0.300 (7.6 mm) |
| Distance between corresponding dots in adjacent cells | 0.025 (0.6 mm) to 0.027 (0.7 mm) | 0.395 (10.0 mm) to 0.400 (10.2 mm) |




Fig. 703.5



Fig. 703.5